

Daily Generation Report of 16 June - 2024

Reporting Date 17 June - 2024

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. In FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)							Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons	Total					
1	CHIBRO	4x60=240	0.192	0.584	0.339	1.129	2.244	31.720	139.292							0.000	185	78	68	0.613	
2	KHODRI	4x 30 = 120	0.356	0.069	0.565	0.132	1.122	16.064	71.063							0.000	86	72	65	0.273	
3	DHAKRANI	3x11.25=33.75	RMU	0.175	0.222		0.397	5.640	20.500							0.000	20	58	58	0.119	Unit 1 is in RMU since 16.02.2024
4	DHALIPUR	3x17 = 51	0.383	RO	0.289		0.672	9.520	35.787							0.000	33	65	72	0.219	
5	KULHAL	3x 10= 30	0.124	0.198	0.103		0.425	6.163	22.966							0.000	20	67	71	0.150	
6	TILOTH (MB-I)	3x30=90	0.717	0.717	0.767		2.201	34.962	110.989							0.000	92	102	102	2.201	
7	DHARASU (MB-II)	4x 76 = 304	1.646	1.802	1.808	1.784	7.040	100.480	322.214							0.000	292	97	97	0.877	
8	CHILLA	4x 36 = 144	0.666	0.666	PO	0.522	1.854	10.053	108.818							0.000	90	63	24	0.262	Unit 3 is in CM since 11.02.2024
9	RAMGANGA	3x 66 = 198	0.810	0.912	0.912		2.634	34.920	126.667							0.000	109	55	46	2.634	
10	KHATIMA	3x 13.8 =41.40	0.136	0.288	0.287		0.711	10.638	41.171		0.001					0.001	32	78	82	0.181	Due to Grid disturbance
11	PATHRI	3x6.8=20.4	0.143	0.148	0.148		0.439	6.575	29.864							0.000	20.4			0.065	
12	MOHD. PUR	3x 3.1 =9.30	0.055	0.057	0.058		0.170	2.646	11.202							0.000	7.6			0.035	
13	GALOGI	3X1+0.5 = 3.5	0.000	PO	RO	0.013	0.013	0.208	1.083							0.000	0.6			0.002	Unit 2 is in CM since 10.05.2024
14	DUNAO	2x.75=1.5	RO	0.001			0.001	0.032	0.23							0.000	0.6			0.000	
15	PILANG GAD	2x1.125=2.25	0.020	0.017			0.037	0.359	2.323							0.000	1.7			0.010	
16	URGAM	2x1.5=3.00	0.028	0.030			0.058	0.829	2.815							0.000	2.5			0.015	
17	KALIGANGA-I	2x2=4.00	0.037	RO			0.037	0.615	2.486							0.000	2.0			0.010	
18	VYASI	2x60=120	0.072	0.069			0.141	2.541	20.266							0.000	45			0.141	
19	KALIGANGA-II	2x2.25=4.5	0.047	0.052			0.098	1.153	3.409							0.000	4.5			0.025	
20	SURINGAD-II	2x2.5=5	RO	RO			0.000	0.000	0.071							0.000	0.0			0.000	
TOTAL							20.295	275.119	1073.211	0.000	0.001	0.000	0.000	0.000	0.000	0.001	1042.90			7.832	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:- Chairman /Secretary(Energy) Govt of Uttrakhand.
MD UJVNL/MD UPCL
Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)