

Daily Generation Report of 19 October - 2024

Reporting Date 20 October - 2024

| SL NO | Name Of Power Station | CAPACITY (MW)  | GENERATION OF THE DAY (MU) |        |        |        |        | Cumulative Gen. of the month till date (MU) | Cumulative Gen. in FY till date (MU) | LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU) |                                 |                                     |                      |                |                         | Declared Capacity (MW)/ Peak Load | PAF of the Day | Av PAF of the month | Generation in M/E Peaking hrs (MU) | Remarks |   |  |
|-------|-----------------------|----------------|----------------------------|--------|--------|--------|--------|---|--------------------------------------|---|---------------------------------|-------------------------------------|----------------------|----------------|-------------------------|-----------------------------------|----------------|---------------------|------------------------------------|---------|---|--|
|       |                       |                | Unit-1                     | Unit-2 | Unit-3 | Unit-4 | Total  |   |                                      | B/D of Equipment  | System Condition & Grid Failure | Flushing & choking / High Head Loss | Flood Pass/ High PPM | Planned Outage | Unusual & Other Reasons |                                   |                |                     |                                    |         | Total   |  |
| 1     | CHIBRO                | 4x60=240       | 0.336                      | 0.750  | PO     | 0.522  | 1.609  | 42.120                                      | 604.681                              |   |                                 |                                     |                      |                |                         | 0.000                             | 160            | 67                  | 73                                 | 0.524   | Unit 3 is in AM since 07.10.2024  |  |
| 2     | KHODRI                | 4x 30 = 120    | 0.389                      | 0.179  | 0.243  | PO     | 0.811  | 21.091                                      | 287.725                              |   |                                 |                                     |                      |                |                         | 0.000                             | 78             | 66                  | 68                                 | 0.240   | Unit 4 is in AM since 07.10.2024  |  |
| 3     | DHAKRANI              | 3x11.25=33.75  | RMU                        | 0.221  | 0.154  |        | 0.375  | 8.196                                       | 72.616                               |   |                                 |                                     |                      | 0.021          |                         | 0.021                             | 19             | 55                  | 55                                 | 0.110   | Unit 1 is in RMU since 16.02.2024   |  |
| 4     | DHALIPUR              | 3x17 = 51      | 0.391                      | 0.065  | 0.257  |        | 0.712  | 18.343                                      | 160.461                              |   |                                 |                                     |                      |                |                         | 0.000                             | 50             | 99                  | 99                                 | 0.180   |   |  |
| 5     | KULHAL                | 3x 10= 30      | 0.204                      | 0.203  | 0.030  |        | 0.437  | 11.130                                      | 96.482                               |   |                                 |                                     |                      |                |                         | 0.000                             | 30             | 101                 | 101                                | 0.150   |   |  |
| 6     | TILOTH (MB-I)         | 3x30=90        | 0.435                      | 0.565  | 0.319  |        | 1.318  | 33.042                                      | 361.069                              |   |                                 |                                     |                      |                |                         | 0.000                             | 94             | 105                 | 105                                | 0.775   |   |  |
| 7     | DHARASU (MB-II)       | 4x 76 = 304    | PO                         | 1.507  | 0.610  | 0.374  | 2.491  | 67.516                                      | 1059.166                             |   |                                 |                                     |                      |                |                         | 0.000                             | 231            | 77                  | 90                                 | 0.694   | Unit 1 is in AM since 16.10.2024  |  |
| 8     | CHILLA                | 4x 36 = 144    | 0.714                      | 0.545  | 0.154  | RO     | 1.413  | 40.527                                      | 407.515                              | 0.001   |                                 |                                     |                      |                |                         | 0.001                             | 66             | 46                  | 70                                 | 0.282   | Due to Thrust bearing temp high in Unit 2                                     |  |
| 9     | RAMGANGA              | 3x 66 = 198    | RO                         | RO     | PO     |        | 0.000  | 0.000                                       | 157.302                              |   |                                 |                                     |                      |                |                         | 0.000                             | 0              | 0                   | 0                                  | 0.000   | Unit 3 is in AM since 29.08.2024  |  |
| 10    | KHATIMA               | 3x 13.8 =41.40 | 0.329                      | 0.342  | RO     |        | 0.671  | 12.197                                      | 120.989                              |   |                                 |                                     |                      |                |                         | 0.000                             | 28             | 68                  | 69                                 | 0.170   |   |  |
| 11    | VYASI                 | 2x60=120       | 0.648                      | FO     |        |        | 0.648  | 21.113                                      | 252.417                              |   |                                 |                                     |                      |                |                         | 0.000                             | 60             |                     |                                    | 0.648   | Unit 2 is in FO due to Bypass valve problem                                   |  |
| 12    | PATHRI                | 3x6.8=20.4     | PO                         | PO     | PO     |        | 0.000  | 3.983                                       | 65.210                               |   |                                 |                                     |                      |                |                         | 0.000                             | 0.0            |                     |                                    | 0.000   | Unit 1 & Unit 2 is in AM since 13.10.2024<br>Unit 3 is in CM since 13.10.2024 |  |
| 13    | MOHD. PUR             | 3x 3.1 =9.30   | RO                         | PO     | PO     |        | 0.000  | 1.788                                       | 25.823                               |   |                                 |                                     |                      |                |                         | 0.000                             | 0.0            |                     |                                    | 0.000   | Canal closure since 12.10.2025<br>Unit 2 & Unit 3 is in AM since 14.10.2024   |  |
| 14    | GALOGI                | 3X1+0.5 = 3.5  | 0.001                      | RO     | 0.011  | 0.022  | 0.034  | 0.655                                       | 4.389                                |   |                                 |                                     |                      |                |                         | 0.000                             | 1.7            |                     |                                    | 0.005   |   |  |
| 15    | DUNAO                 | 2x.75=1.5      | 0.007                      | 0.005  |        |        | 0.012  | 0.245                                       | 1.58                                 |   |                                 |                                     |                      |                |                         | 0.000                             | 0.9            |                     |                                    | 0.005   |   |  |
| 16    | PILANG GAD            | 2x1.125=2.25   | RO                         | 0.016  |        |        | 0.016  | 0.241                                       | 3.622                                |   |                                 |                                     |                      |                |                         | 0.000                             | 0.9            |                     |                                    | 0.004   |   |  |
| 17    | URGAM                 | 2x1.5=3.00     | RO                         | RO     |        |        | 0.000  | 0.022                                       | 3.854                                |   |                                 |                                     |                      |                |                         | 0.000                             | 0.0            |                     |                                    | 0.000   |   |  |
| 18    | KALIGANGA-I           | 2x2=4.00       | 0.033                      | RO     |        |        | 0.033  | 0.811                                       | 8.559                                |   |                                 |                                     |                      |                |                         | 0.000                             | 2.0            |                     |                                    | 0.011   |   |  |
| 19    | KALIGANGA-II          | 2x2.25=4.5     | 0.048                      | 0.021  |        |        | 0.068  | 0.873                                       | 8.771                                |   |                                 |                                     |                      |                |                         | 0.000                             | 4.5            |                     |                                    | 0.024   |   |  |
| 20    | SURINGAD-II           | 2x2.5=5        | RO                         | RO     |        |        | 0.000  | 0.000                                       | 0.071                                |   |                                 |                                     |                      |                |                         | 0.000                             | 0.0            |                     |                                    | 0.000   |   |  |
| 21    | MADHYAMAHESHWAR       | 3x5=15         | RO                         | 0.122  | RO     |        | 0.122  | 2.200                                       | 9.681                                |   |                                 |                                     |                      |                |                         | 0.000                             | 5.0            |                     |                                    | 0.030   |   |  |
| TOTAL |                       |                |                            |        |        |        | 10.770 | 286.094                                     | 3711.983                             | 0.001   | 0.000                           | 0.000                               | 0.000                | 0.021          | 0.000                   | 0.022                             | 830.50         |                     |                                    |         | 3.852   |  |

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-  
 Chairman /Secretary(Energy) Govt of Uttarakhand.  
 MD UJVNL/MD UPCL  
 Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)