

Daily Generation Report of 06 October - 2024

Reporting Date 07 October - 2024

SL NO	Name Of Power Station	CAPACITY (MW)	GENERATION OF THE DAY (MU)					Cumulative Gen. of the month till date (MU)	Cumulative Gen. in FY till date (MU)	LOSS OF GENERATION ACCORDING TO WATER AVAILABILITY w.r.t. MACHINE CAPACITY (MU)						Declared Capacity (MW)/ Peak Load	PAF of the Day	Av PAF of the month	Generation in M/E Peaking hrs (MU)	Remarks	
			Unit-1	Unit-2	Unit-3	Unit-4	Total			B/D of Equipment	System Condition & Grid Failure	Flushing & choking / High Head Loss	Flood Pass/ High PPM	Planned Outage	Unusual & Other Reasons						Total
1	CHIBRO	4x60=240	0.346	1.085	0.662	0.448	2.542	16.763	579.324							0.000	195	82	82	0.649	
2	KHODRI	4x 30 = 120	0.505	0.466	0.139	0.142	1.251	8.210	274.844							0.000	88	74	74	0.282	
3	DHAKRANI	3x11.25=33.75	RMU	0.214	0.249		0.463	2.763	67.183					0.192		0.192	19	55	55	0.105	Unit 1 is in RMU since 16.02.2024
4	DHALIPUR	3x17 = 51	0.384	0.381	0.385		1.149	7.068	149.187							0.000	50	99	99	0.201	
5	KULHAL	3x 10= 30	0.221	0.232	0.221		0.675	4.166	89.517							0.000	30	101	101	0.150	
6	TILOTH (MB-I)	3x30=90	0.622	0.800	0.802		2.223	13.502	341.529							0.000	94	105	105	2.223	
7	DHARASU (MB-II)	4x 76 = 304	1.317	1.544	0.467	0.918	4.246	31.665	1023.315							0.000	287	95	96	1.144	
8	CHILLA	4x 36 = 144	0.634	0.666	0.641	0.555	2.496	16.828	383.816							0.000	118	83	87	0.375	
9	RAMGANGA	3x 66 = 198	RO	PO	PO		0.000	0.000	157.302							0.000	0	0	0	0.000	Unit 2 is in AM since 21.08.2024, Unit 3 is in AM since 29.08.2024
10	KHATIMA	3x 13.8 =41.40	0.362	RO	0.359		0.721	3.861	112.653							0.000	30	73	69	0.180	
11	VYASI	2x60=120	0.221	1.063			1.284	8.874	240.178							0.000	120			1.282	
12	PATHRI	3x6.8=20.4	0.134	0.126	0.114		0.373	1.915	63.141							0.000	16.6			0.066	
13	MOHD. PUR	3x 3.1 =9.30	0.049	0.058	0.057		0.165	0.868	24.903							0.000	7.3			0.035	
14	GALOGI	3X1+0.5 = 3.5	0.006	RO	0.010	0.021	0.036	0.223	3.958							0.000	1.7			0.005	
15	DUNAO	2x.75=1.5	0.008	0.006			0.014	0.083	1.42							0.000	1.0			0.004	
16	PILANG GAD	2x1.125=2.25	RO	0.015			0.015	0.068	3.449							0.000	0.7			0.004	
17	URGAM	2x1.5=3.00	RO	RO			0.000	0.022	3.854							0.000	0.0			0.000	
18	KALIGANGA-I	2x2=4.00	0.043	0.022			0.065	0.375	8.122							0.000	4.0			0.023	
19	KALIGANGA-II	2x2.25=4.5	0.027	RO			0.027	0.177	8.076							0.000	2.3			0.009	
20	SURINGAD-II	2x2.5=5	RO	RO			0.000	0.000	0.071							0.000	0.0			0.000	
21	MADHYAMAHESHWAR	3x5=15	RO	0.121	RO		0.121	0.724	8.205							0.000	5.0			0.030	
TOTAL							17.866	118.155	3544.044	0.000	0.000	0.000	0.000	0.192	0.000	0.192	1069.00			6.768	

AM - Annual Maintenance, CM-Capital Maintenance, PO - Planned Outage, RO - Reserve Outage, FO - Forced Outage, RMU - Renovation, Modernization and Upgradation, T & C-Testing & Commissioning

Distributed to:-
 Chairman /Secretary(Energy) Govt of Uttrakhand.
 MD UJVNL/MD UPCL
 Director(Operation) /Director(Project)/Director(Finance)/ Director(HR)

Dy. General Manager (Technical)