


For better participation and on request from the prospective bidders, it is proposed to extend the dates of submission and opening with corrigendum against NIT no. e-22/UJVNL/EE (M&G)/KPS/2022-23 “S.I.T.C of Nitrogen Injection Fire Protection System for 6.6/132 kV, 12.5 MVA Generator Transformer of Unit A & C as under:

Corrigendum:

SL NO	<u>AS PER TENDER</u>	<u>Approved Changes</u>
1.	<p>Page-46 of Tender BID Tender specification</p> <p>CUBICLE (FEC):- Oil drain pipe with mechanical quick drain valve. Oil drain pipe extension of suitable sizes for connecting pipes to oil pit.</p>	<p>CUBICLE (FEC):- Oil drain pipe with mechanical quick drain valve. Oil drain pipe extension of suitable sizes for connecting pipes to oil pit. <i>The Oil drain pipe may or may not be the part of FEC.</i></p>
2.	<p>Page-48 of Tender BID Tender specification</p> <p>Fire detectors: The system will be complete with adequate number of fire detectors 141°C (quartz bulb) fitted on the top cover of the transformer oil tank for sensing fire and shall be located at strategic locations specifically bushings/cable box, OLTC, PRV etc</p>	<p>Fire detectors: The system will be complete with adequate number of fire detectors 141°C (quartz bulb/ metallic stainless steel tube type) fitted on the top cover of the transformer oil tank for sensing fire and shall be located at strategic locations specifically bushings/cable box, OLTC, PRV etc</p>
3.	<p>Page-49 of Tender BID Tender specification</p> <p>Transformer Conservator Isolation valve Setting 60 ltr / min (Minimum)</p>	<p>Transformer Conservator Isolation valve Setting: 40-60 ltr / min</p>

	<p style="text-align: center;">यूजेवीएन लि० ख्यालय: "उज्जवल", महारानीबाग, जी०एम०एस० रोड, देहरादून सी०आई०न०. U40101UR2001SGC025866 दूरभाष सं० 0135-2763508, फ़ैक्स सं० 0135-2763507</p>				
	निविदा तिथि विस्तार सूचना				
अपरिहार्य	कारणों	से	निविदा	सं०	ई
<p>22/यूजेवीएनलि० /अअ(अनुएवंउ०) /केपीएस / 2022-23: कुल्हाल विद्युत गृह में युनिट ए और सी के 6.6/132 के०वी० 12.5 एमवीए जेनरेटर ट्रंसफार्मर के लिए नाइट्रोजन इंजेक्शन अग्नि सुरक्षा प्रणाली का S.I.T.C का कार्य के सम्बन्ध में शुद्धि पत्र http://uktenders.gov.in पर अपलोड कर निविदा को खोलने एवं जमा करने की तिथियां निम्नवत विस्तारित की जाती हैं-</p> <p>निविदा जमा करने की अन्तिम तिथि : 25.01.2023, 17:00 बजे हार्ड कॉपी जमा करने की अन्तिम तिथि : 30.01.2023, 17:00 बजे निविदा खोलने की तिथि : 31.01.2023, 11:00 बजे</p> <p>निविदा की अन्य शर्तें पूर्ववत अन्य जानकारी हेतु कृपया हमारी वेबसाइट देखें। निविदा प्रपत्र निगम की वेबसाइट http://uktenders.gov.in से डाउनलोड किये जा सकते हैं।</p> <p style="text-align: right;">अधिशाली अभियन्ता(अन० एवं उ०), कुल्हाल</p>					
“बिजली की बर्बादी पूर्ण उपयोग ना करें”					

	<p style="text-align: center;">UJVN LIMITED H.O.: "Ujjwal", Maharani Bagh, GMS Road, Dehradun-248001 CIN No.U40101UR2001SGC025866 (Tel.: 0135-2763508, Fax: 0135-2763507)</p>				
	Date Extension Notice				
<p>Due to unavoidable reasons, after uploading corrigendum on http://uktenders.gov.in, the last date of submission and opening of NIT no. e- 22/UJVNL/EE (M&G)/KPS/2022-23 "S.I.T.C of Nitrogen Injection Fire Protection System for 6.6/132 kV, 12.5 MVA Generator Transformer of Unit A & C installed at Kulhal Power Station" is hereby extended as under-</p> <p>Last date for submission of tender : 25.01.2023, 17:00 Hrs. Last date for submission of hard copy : 30.01.2023, 17:00 Hrs. Date of opening of tender : 31.01.2023, 11:00 Hrs.</p> <p>For fuller & further details, kindly visit our website. The tender documents can be downloaded from the Nigam's website "http://uktenders.gov.in"</p> <p style="text-align: right;">Executive Engineer (M&G), Kulhal</p>					
“Avoid wasteful use of electricity”					